



# The PI System – Data Hub









# Water Operations Dashboard – Prior State

## Water Operations Daily Report December 31, 2016



|      | Saturday,<br>12/31/16<br>High °F | Temp<br>High °F | Total<br>Annual<br>Rainfall<br>in. | Average<br>Annual<br>Rainfall<br>in. (30 years) | Year to Date<br>Gallons of Potable<br>Water Produced* | Daily Average &<br>2015 Total<br>(Gallons) | % Difference<br>from Previous<br>Year |
|------|----------------------------------|-----------------|------------------------------------|---|---|--|---------------------------------------|
| 2016 | 57                               | 111             | 7.91                               | 12.7  | 21,621,930,000  | 54,190,301                                 | 2.4%                                  |
| 2015 |                                  | 108             | 6.77                               |   | 21,119,600,000  | 21,119,600,000                             |                                       |

\* 2015 Year to Date based on same day of previous year



### Daily Deliveries MGD

|                         | MGD | Daily Average | 2015 Daily Average |
|-------------------------|-----|---------------|--------------------|
| WMWD <sub>1</sub>       | 7.0 | 6.9           | 5.8                |
| Gage Canal              | 0.0 | 5.5           | 3.5                |
| Lower Gage <sub>2</sub> | 0.0 | 2.5           | 2.9                |

<sub>1</sub> WMWD daily maximum ~ 10 MGD <sub>2</sub> Non-Potable

### Daily Potable Production Statistics MGD

|             | MGD  | Daily Average | 2015 Daily Average |
|-------------|------|---------------|--------------------|
| Bunker Hill | 24.8 | 38.2          | 42.3               |
| N. Orange   | 4.1  | 8.7           | 6.6                |
| JW North    | 6.0  | 3.6           | 1.5                |
| VB Wells    | 0.0  | 3.6           | 2.8                |

### Water Quality Compliance

| Analyte     | Comply | MCL <sub>5</sub> |
|-------------|--------|------------------|
| Nitrate     | Yes    | 10 ppm           |
| Perchlorate | Yes    | 6 ppb            |
| Uranium     | Yes    | 20 pCi/L         |
| TCE/DBCP    | Yes    | 5 ppb/0.2 ppb    |

Questions? x5612


ppm = part per million ppb = part per billion pCi/L = Picocuries/liter




# Water Operations Dashboard

[Home](#) / [Water](#) / [Water Operations](#)

### Cumulative Daily System Demand



### Monthly Bunker Hill & Riverside Groundwater Production Target vs Actual (AF)



Today's High Temp Forecast

57 F

Today's Current Temperature

54 F

Current Water Production

36.9MGD

YTD Prod. Potable Water 2,019

2 BG  
% Diff -26.1▼


YTD Prod. Potable Water 2,018

2.7 BG


Total 2,018

23.6 BG


### Production (MG) by Transmission Line




### Water Delivery (MG) Potable & Non Potable




### Potable Production (MG) by Basin




### Reservoir Level 91.1 MG




### Bunker Hill Production Target = 61,898 acre feet




### Riverside Production Target = 22,245 acre feet



### WMWD Potable Delivery Target = 8,008 acre feet













# Enterprise Monitoring – Secure Browser Access to SCADA

***InTouch Access Anywhere*** is used to extend access to ***HMI applications*** to *mobile, casual* and *non-traditional* users using a wide variety of devices enabled with an HTML5 compliant browser.

- Desktops
- Laptops
- Tablets
- Smart phones
- Smart TVs
- And more!




- Safari
- Google Chrome
- Internet Explorer
- Firefox
- Opera
- And more!




# Plant Model: Example

- 15 Areas
- 120 PLCs
  - 78 PLCs on the LTP Ethernet LAN
  - 36 PLCs on Serial Radios for Collection and Reuse
- 6 PLCs on Ethernet Radios
  - 4 at LTP
  - 2 for the Reuse System




# Build & Reuse Standards




# Example RTU Template

- Templates can be used with multiple similar equipment installations
- RTU Template
  - 36 Instances



# RTU Graphic Template





# SCADA RTU Screen

InTouch - WindowViewer - C:\PROGRAMDATA\ARCHESTRA\MANAGEDAPP

File Logic Special Development!

|                               |                             |                             |                             |                             |                           |                              |                            |                               |
|-------------------------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|---------------------------|------------------------------|----------------------------|-------------------------------|
| <b>Low Master</b>             | <b>RTU1</b><br>E Pmp Plnt   | <b>RTU2</b><br>Todd         | <b>RTU3</b><br>D-Pond       | <b>RTU4</b><br>Spare        | <b>RTU5</b><br>Spare      | <b>RTU6</b><br>Alpha         | <b>RTU7</b><br>Kelly       | <b>RTU8</b><br>W Coll Pmp     |
|                               | Rspnce Sec                  | Rspnce Sec                  | Rspnce Sec                  | Rspnce Sec                  | Rspnce Sec                | Rspnce Sec                   | Rspnce Sec                 | Rspnce Sec                    |
|                               | 4                           | 0                           | 4                           | 0                           | 0                         | 3                            | 4                          | 4                             |
|                               | Enabled                     | Disabled                    | Enabled                     |                             |                           | Enabled                      | Enabled                    | Enabled                       |
| Active RTU                    | Com OK                      | Com OK                      | Com OK                      |                             |                           | Com OK                       | Com OK                     | Com OK                        |
| Total Rspnce Time Seconds     | <b>RTU9</b><br>Spare        | <b>RTU10</b><br>Carinelli   | <b>RTU11</b><br>North Pmp   | <b>RTU12</b><br>RP Pump     | <b>RTU13</b><br>Meadow Ln | <b>RTU14</b><br>Place 2 Play | <b>RTU15</b><br>Aggio/Glea | <b>RTU16</b><br>Peter's Dairy |
| 72                            | Rspnce Sec                  | Rspnce Sec                  | Rspnce Sec                  | Rspnce Sec                  | Rspnce Sec                | Rspnce Sec                   | Rspnce Sec                 | Rspnce Sec                    |
| Interpoll Delay Timer Seconds | 0                           | 0                           | 7                           | 3                           | 4                         | 5                            | 0                          | 0                             |
| 2.0                           |                             | Disabled                    | Enabled                     | Enabled                     | Enabled                   | Enabled                      | Disabled                   | Disabled                      |
| Rspnce Timeout Seconds        |                             | Com OK                      | Com OK                      | Com OK                      | Com OK                    | Com OK                       | Com OK                     | Com OK                        |
| 8.0                           | <b>RTU17</b><br>Ambrosini   | <b>RTU18</b><br>Brn Trailer | <b>RTU19</b><br>Dotti       | <b>RTU20</b><br>Rnch Laguna | <b>RTU21</b><br>Fulton Rd | <b>RTU22</b><br>Stone Farm   | <b>RTU23</b><br>Spare      | <b>RTU24</b><br>W Pmp Plnt    |
| Pass Count                    | Rspnce Sec                  | Rspnce Sec                  | Rspnce Sec                  | Rspnce Sec                  | Rspnce Sec                | Rspnce Sec                   | Rspnce Sec                 | Rspnce Sec                    |
| 2                             | 5                           | 4                           | 0                           | 0                           | 4                         | 4                            | 0                          | 0                             |
| RTU High Master               | Enabled                     | Enabled                     | Disabled                    | Disabled                    | Enabled                   | Enabled                      |                            | Disabled                      |
| Main Menu                     | Com OK                      | Com OK                      | Com OK                      | Com OK                      | Com OK                    | Com OK                       |                            | Com OK                        |
| Alarms                        | <b>RTU25</b><br>LaFran Pipe | <b>RTU26</b><br>Mello East  | <b>RTU27</b><br>LaFran Pond | <b>RTU28</b><br>Spare       | <b>RTU29</b><br>Spare     | <b>RTU30</b><br>Spare        | <b>RTU31</b><br>Spare      | <b>RTU32</b><br>Spare         |
|                               | Rspnce Sec                  | Rspnce Sec                  | Rspnce Sec                  | Rspnce Sec                  | Rspnce Sec                | Rspnce Sec                   | Rspnce Sec                 | Rspnce Sec                    |
|                               | 0                           | 0                           | 0                           | 0                           | 0                         | 0                            | 0                          | 0                             |
|                               | Disabled                    | Disabled                    | Disabled                    |                             |                           |                              |                            |                               |
|                               | Com OK                      | Com OK                      | Com OK                      |                             |                           |                              |                            |                               |

# Best Practice: Alarm signaling in the HMI


- 1 Severity 1 **Critical** response time < 5min
- 2 Severity 2 **High** response time < 30min
- 3 Severity 3 **Medium** response time < 60min
- 4 Severity 4 **Low** response time < 120min

## Triple Coding: Shape, Color, Identifier

| Priority | Safety Risk | Economic Loss | Environmental Risk |
|----------|-------------|---------------|--------------------|
| Critical | > 0.1       | > \$100,000   | > 0.1              |
| High     | > 0.01      | > \$10,000    | > 0.01             |
| Medium   | > 0.001     | > \$1,000     | > 0.001            |
| Low      | < 0.001     | < \$1,000     | < 0.001            |


Operational risk of the Alarms.

| Priority | Operational                                  |
|----------|--|
| Critical | Total loss of plant                          |
| High     | Loss of plant area                           |
| Medium   | Loss of equipment → loss of production       |
| Low      | Loss of equipment without loss of production |




# California State Water Project

- Secure, Centralized Data Collection & Reporting from Distributed Application
- Equipment Runtimes
- Flows, Volumes
- Operational Availability Reports
- Environmental Reports
- Water Demand Scheduling and modeling



Discrepancies were found averaging 2-3 MGD, saving an average of 18,000 a month

[illegible]

| <div>  <div> City of Rohnert Park<br/> Waste Water Total Flow Monthly Report </div> </div> |           |             |           |                     |
|---|-----------|-------------|-----------|---------------------|
|   |           | Start Date: | 11/2017   |                     |
|   |           | End Date:   | 11/2017   |                     |
| Day   | Station 1 | Station 2   | Station 3 | Station 1 + 2 total |
| 1   | 0.585     | 2.675       | 0.001     | 3.260               |
| 2   | 0.661     | 2.727       | 0.001     | 3.388               |
| 3   | 0.964     | 3.364       | 0.002     | 4.328               |
| 4   | 0.231     | 5.665       | 0.003     | 5.896               |
| 5   | 0.009     | 4.778       | 0.002     | 4.787               |
| 6   | 0.038     | 4.249       | 0.000     | 4.287               |
| 7   | 0.159     | 4.451       | 0.000     | 4.610               |
| 8   | 0.862     | 8.639       | 0.000     | 9.501               |
| 9   | 0.598     | 7.107       | 0.000     | 7.705               |
| 10  | 0.865     | 8.881       | 0.005     | 9.746               |
| 11  | 0.727     | 7.850       | 0.000     | 8.577               |
| 12  | 0.498     | 6.915       | 0.000     | 7.413               |
| 13  | 0.146     | 5.917       | 0.002     | 6.063               |
| 14  | 0.130     | 5.322       | 0.002     | 5.453               |
| 15  | 0.067     | 4.922       | 0.002     | 4.989               |
| 16  | 0.046     | 4.713       | 0.002     | 4.760               |
| 17  | 1.069     | 3.318       | 0.002     | 4.387               |
| 18  | 0.302     | 5.443       | 0.000     | 5.745               |
| 19  | 0.300     | 7.057       | 0.000     | 7.357               |
| 20  | 0.456     | 7.965       | 0.000     | 8.421               |
| 21  | 0.563     | 6.889       | 0.003     | 7.452               |
| 22  | 0.473     | 8.690       | 0.000     | 9.162               |
| 23  | 0.852     | 6.938       | 0.000     | 7.791               |
| 24  | 0.315     | 6.367       | 0.002     | 6.682               |
| 25  | 0.090     | 5.661       | 0.002     | 5.751               |
| 26  | 0.639     | 2.134       | 0.000     | 2.773               |
| 27  | 0.626     | 2.167       | 0.000     | 2.793               |
| 28  | 0.129     | 4.656       | 0.002     | 4.786               |
| 29  | 0.211     | 4.555       | 0.002     | 4.766               |
| 30  | 0.038     | 4.403       | 0.000     | 4.442               |
| 31  | 0.037     | 4.224       | 0.000     | 4.261               |
| Totals  | 12.654    | 164.418     | 0.035     | 177.072             |



- Creating reports in-house saves time and money and provides flexibility
- Reports can be generated in any format
- Automatically get generated and distributed to clients- via email

## Reports can be generated in any format

Automatically get generated and distributed to clients- via email



File

Home

Sent / Receive

Folder

View

Attachments

Open

Quick Print

Save As

Save All Attachments

Remove Attachment

Select All

Copy

Show Message

Actions

Selection

Show Message

Drag Your Favorite Folders

GSandhu@svcw.org

Inbox

RMS

RMS Alarms

Bobby

Cascadeid

Cerlic

Chillers

Chuck

Endress Houser

Fieldserver

Gurpal

HachWims

James Lostica

Kip

Nate

Reports

Rockwell

Wonderware

Drafts [1]

Sent Items

Deleted Items [24]

Archive

Junk E-Mail [34]

Outbox

RSS Feeds

Search Folders

Outlook Data File

Inbox

Drafts

Sent Items

Deleted Items

Junk E-mail

Outbox

RSS Feeds

Search Folders

Mail

Calendar

Contacts

Tasks

Search Reports (Ctrl+E)

Arrange By: Date

Newest on top

Wonderware Reports

4/1/2017

▼

Daily Report- Wet Side

Wonderware Reports

4/1/2017

▼

Monthly Report- Wet Side Excel

Wonderware Reports

4/1/2017

▼

Monthly Report- Dry Side

Wonderware Reports

4/1/2017

▼

Monthly Report- Wet Side

Wonderware Reports

3/31/2017

▼

Monthly Report- Recycle Water

Wonderware Reports

3/31/2017

▼

Daily Report- Recycle Water

Wonderware Reports

3/31/2017

▼

Daily Report- Final Eff Monitoring

Wonderware Reports

3/31/2017

▼

Daily Foulmer Report New

Wonderware Reports

3/30/2017

▼

Daily Report- Wet Side

Wonderware Reports

3/30/2017

▼

Daily Report- Recycle Water

Wonderware Reports

3/30/2017

▼

Daily Report- Final Eff Monitoring

Wonderware Reports

3/30/2017

▼

Daily Foulmer Report New

Wonderware Reports

3/29/2017

▼

Daily Report- Dry Side

Wonderware Reports

3/29/2017

▼

Daily Report- Wet Side

Wonderware Reports

3/29/2017

▼

Daily Report- Recycle Water

Wonderware Reports

3/29/2017

▼

Daily Report- Final Eff Monitoring

Wonderware Reports

3/29/2017

▼

Daily Foulmer Report New

Wonderware Reports

3/28/2017

▼

Daily Report- Dry Side

Wonderware Reports

3/28/2017

▼

Daily Report- Wet Side

Wonderware Reports

3/28/2017

▼

Daily Report- Recycle Water

Wonderware Reports

3/28/2017

▼

Daily Report- Final Eff Monitoring

Wonderware Reports

3/28/2017

▼

Daily Foulmer Report New

Wonderware Reports

3/27/2017

▼

Daily Foulmer Report New

Wet Side\_3\_31\_2017 11\_55\_00 PM.xls

Size: 62 KB

Author: SVCW WW

Last changed: Wednesday, July 22, 2015

Message

Wet Side\_3\_31\_2017 11\_55\_00 PM.xls [62 KB]

1

A

B

C

D

E

F

G

H

I

J

K

L

2

Pump Stations Report

3

Date

MP Flow Tot (MGal)

RW Flow Tot (MGal)

SC Flow Tot (MGal)

BM Flow Tot (MGal)

RWS Flow Tot (MGal)

MP Flow Min (MGal)

MP Flow Max (MGal)

RW Flow Min (MGal)

RW Flow Max (MGal)

SC Flow Min (MGal)

4

03/01/2017

4.38

8.13

3.08

2.24

1.16

0.32

8.94

3.03

16.45

0.69

5

03/02/2017

4.37

7.86

2.96

2.12

1.12

0.37

7.57

3.94

13.88

0.68

6

03/03/2017

4.06

9.63

3

2.11

1.05

0.32

8.35

5.37

13.44

0.68

7

03/04/2017

3.71

9.98

3.16

2.38

1

0.3

9.28

4.44

13.46

0.68

8

03/05/2017

4.64

9.05

6.61

4.13

1.24

1.13

7.5

6.23

12.63

3.33

9

03/06/2017

4.92

8.77

5.32

3.66

1.35

0.46

13.67

0.57

13.31

2.2

10

03/07/2017

4.73

8.96

4.12

2.91

1.25

0.29

9.84

3.88

13.48

0.68

11

03/08/2017

4.52

10.12

3.66

2.6

1.19

0.91

10.29

4.98

19.56

0.7

12

03/09/2017

3.55

8.6

3.5

2.41

1.13

0.28

7.5

4.65

14.98

0.8

13

03/10/2017

4.76

7.73

3.26

2.22

1.09

0.28

10.53

0.56

15.32

0.71

14

03/11/2017

3.73

7.84

3.04

2.2

0.96

0.68

6.81

4.36

13.79

0.68

15

03/12/2017

3.58

7.46

2.83

2.17

0.95

0.68

6.29

4.44

14.58

0.69

16

03/13/2017

4.38

7.28

2.96

2.09

1

0.68

9.79

0.56

13.08

0.68

17

03/14/2017

4.19

7.55

2.77

2.03

1.07

0.75

10.37

1.21

14.19

0.67

18

03/15/2017

4.09

7.24

2.71

1.99

1.05

0.29

8.71

3.71

13.14

0.68

19

03/

# CIQWS / eSMR / PET Tool Reporting

Home > Org130806 > UT86-0009

From Date: 4/1/2019 To Date: 4/30/2019

View Report

| Monitoring Point | Parameter | Data Type            | Analytical Method | Collection Date       | Collection Time | Analysis Date | Qualifier | Result | Units |
|------------------|-----------|----------------------|-------------------|-----------------------|-----------------|---------------|-----------|--------|-------|
| EFF-001          | Flow      | Daily Average (Mean) | Water             | Data Unavailable [DU] | 4/2/2019        | 00:00:00      |           | 26.7   | MGD   |
| EFF-001          | Flow      | Daily Average (Mean) | Water             | Data Unavailable [DU] | 4/3/2019        | 00:00:00      |           | 26.0   | MGD   |
| EFF-001          | Flow      | Daily Average (Mean) | Water             | Data Unavailable [DU] | 4/4/2019        | 00:00:00      |           | 24.8   | MGD   |
| EFF-001          | Flow      | Daily Average (Mean) | Water             | Data Unavailable [DU] | 4/5/2019        | 00:00:00      |           | 28.5   | MGD   |
| EFF-001          | Flow      | Daily Average (Mean) | Water             | Data Unavailable [DU] | 4/6/2019        | 00:00:00      |           | 27.0   | MGD   |
| EFF-001          | Flow      | Daily Average (Mean) | Water             | Data Unavailable [DU] | 4/7/2019        | 00:00:00      |           | 28.5   | MGD   |
| EFF-001          | Flow      | Daily Average (Mean) | Water             | Data Unavailable [DU] | 4/8/2019        | 00:00:00      |           | 26.1   | MGD   |
| EFF-001          | Flow      | Daily Average (Mean) | Water             | Data Unavailable [DU] | 4/9/2019        | 00:00:00      |           | 22.9   | MGD   |

SSRS Report with lab and SCADA summaries from data warehouse, with custom SQL functions for required reporting parameters.



Pet\_April.xls - Compatibility Mode - Excel

McGarey, Matt

File Home Insert Draw Page Layout Formulas Data Review View Add-ins Help ACROBAT Team Historian Tell me what you want to do

E4 Data Unavailable [DU]

| Monitoring Point | Parameter | Data Type            | Analytical Method                 | Collection Date | Collection Time | Analysis Date | Qualifier | Result | Units    | MDL | ML | RL |
|------------------|-----------|----------------------|-----------------------------------|-----------------|-----------------|---------------|-----------|--------|----------|-----|----|----|
| 108              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/15/2019       | 00:00:00        | 4/15/2019     | =         | 33.7   | MGD      |     |    |    |
| 109              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/16/2019       | 00:00:00        | 4/16/2019     | =         | 34.8   | MGD      |     |    |    |
| 110              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/17/2019       | 00:00:00        | 4/17/2019     | =         | 33.1   | MGD      |     |    |    |
| 111              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/18/2019       | 00:00:00        | 4/18/2019     | =         | 34     | MGD      |     |    |    |
| 112              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/19/2019       | 00:00:00        | 4/19/2019     | =         | 37.3   | MGD      |     |    |    |
| 113              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/20/2019       | 00:00:00        | 4/20/2019     | =         | 29.5   | MGD      |     |    |    |
| 114              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/21/2019       | 00:00:00        | 4/21/2019     | =         | 35.2   | MGD      |     |    |    |
| 115              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/22/2019       | 00:00:00        | 4/22/2019     | =         | 29.7   | MGD      |     |    |    |
| 116              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/23/2019       | 00:00:00        | 4/23/2019     | =         | 39.5   | MGD      |     |    |    |
| 117              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/24/2019       | 00:00:00        | 4/24/2019     | =         | 35.5   | MGD      |     |    |    |
| 118              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/25/2019       | 00:00:00        | 4/25/2019     | =         | 34.9   | MGD      |     |    |    |
| 119              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/26/2019       | 00:00:00        | 4/26/2019     | =         | 28.6   | MGD      |     |    |    |
| 120              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/27/2019       | 00:00:00        | 4/27/2019     | =         | 30.1   | MGD      |     |    |    |
| 121              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/28/2019       | 00:00:00        | 4/28/2019     | =         | 33.3   | MGD      |     |    |    |
| 122              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/29/2019       | 00:00:00        | 4/29/2019     | =         | 30     | MGD      |     |    |    |
| 123              | EFF-001   | Flow                 | Daily Maxim Data Unavailable [DU] | 4/30/2019       | 00:00:00        | 4/30/2019     | =         | 30.2   | MGD      |     |    |    |
| 124              | DNT-001A  | Surface Loading Rate | Daily Avera Data Unavailable [DU] | 4/1/2019        | 00:00:00        | 4/1/2019      | =         | 2.6    | gpm/sqft |     |    |    |
| 125              | DNT-001A  | Surface Loading Rate | Daily Avera Data Unavailable [DU] | 4/2/2019        | 00:00:00        | 4/2/2019      | =         | 2.4    | gpm/sqft |     |    |    |
| 126              | DNT-001A  | Surface Loading Rate | Daily Avera Data Unavailable [DU] | 4/3/2019        | 00:00:00        | 4/3/2019      | =         | 2.5    | gpm/sqft |     |    |    |
| 127              | DNT-001A  | Surface Loading Rate | Daily Avera Data Unavailable [DU] | 4/4/2019        | 00:00:00        | 4/4/2019      | =         | 2.2    | gpm/sqft |     |    |    |
| 128              | DNT-001A  | Surface Loading Rate | Daily Avera Data Unavailable [DU] | 4/5/2019        | 00:00:00        | 4/5/2019      | =         | 2.7    | gpm/sqft |     |    |    |
| 129              | DNT-001A  | Surface Loading Rate | Daily Avera Data Unavailable [DU] | 4/6/2019        | 00:00:00        | 4/6/2019      | =         | 2.5    | gpm/sqft |     |    |    |
| 130              | DNT-001A  | Surface Loading Rate | Daily Avera Data Unavailable [DU] | 4/7/2019        | 00:00:00        | 4/7/2019      | =         | 2.6    | gpm/sqft |     |    |    |
| 131              | DNT-001A  | Surface Loading Rate | Daily Avera Data Unavailable [DU] | 4/8/2019        | 00:00:00        | 4/8/2019      | =         | 2.4    | gpm/sqft |     |    |    |
| 132              | DNT-001A  | Surface Loading Rate | Daily Avera Data Unavailable [DU] | 4/9/2019        | 00:00:00        | 4/9/2019      | =         | 2.2    | gpm/sqft |     |    |    |
| 133              | DNT-001A  | Surface Loading Rate | Daily Avera Data Unavailable [DU] | 4/10/2019       | 00:00:00        | 4/10/2019     | =         | 2.3    | gpm/sqft |     |    |    |
| 134              | DNT-001A  | Surface Loading Rate | Daily Avera Data Unavailable [DU] | 4/11/2019       | 00:00:00        | 4/11/2019     | =         | 2.1    | gpm/sqft |     |    |    |

Ready

Output matches format of State Board Excel-based tool for electronic submission on SMR data.

# Power Quality Reporting



## Luther Pass Pump Station Monthly Power Report

Start Date: 2020-08-20 00:00:00  
End Date: 2020-09-20 00:00:00

### Energy Consumption for Report Period

| Begin          | End            | Consumption |
|----------------|----------------|-------------|
| 17,731,304 kWh | 18,246,430 kWh | 515,126 kWh |


### Power Factor for Report Period

| Minimum | Maximum | Average |
|---------|---------|---------|
| 0.06    | 1.00    | 0.74    |

### Maximum Power Measurement

| Timestamp of Maximum Power | Maximum  |
|----------------------------|----------|
| 8/29/2020 22:10:00         | 1,561 kW |

### Summary Power Trend



## Luther Pass Pump Station Monthly Power Report

Start Date: 2020-08-20 00:00:00  
End Date: 2020-09-20 00:00:00

### Power by Pump Combination

| Pumps Running    | Elapsed Time | Energy Consumption | Demand (max kW) |
|------------------|--------------|--------------------|-----------------|
| Pump 1           | 4 hrs        | 0 kWh              | 0 kW            |
| Pump 2           | 148 hrs      | 0 kWh              | 0 kW            |
| Pump 3           | 39 hrs       | 0 kWh              | 0 kW            |
| Pump 4           | 19 hrs       | 0 kWh              | 0 kW            |
| Pump 1 and 2     | 0 hrs        | 0 kWh              | 0 kW            |
| Pumps 1 and 3    | 0 hrs        | 0 kWh              | 0 kW            |
| Pumps 1 and 4    | 0 hrs        | 0 kWh              | 0 kW            |
| Pumps 2 and 3    | 96 hrs       | 0 kWh              | 0 kW            |
| Pumps 2 and 4    | 177 hrs      | 514,948 kWh        | 1,561 kW        |
| Pumps 3 and 4    | 23 hrs       | 0 kWh              | 0 kW            |
| Pumps 1, 2 and 3 | 0 hrs        | 0 kWh              | 0 kW            |
| Pumps 1, 2 and 4 | 0 hrs        | 0 kWh              | 0 kW            |
| Pumps 1, 3 and 4 | 0 hrs        | 0 kWh              | 0 kW            |
| Pumps 2, 3 and 4 | 0 hrs        | 0 kWh              | 0 kW            |

### Power Alarms during Report Period

| Alarm Time         | Tag Name                     | Alarm Text                                  |
|--------------------|------------------------------|---|
| ...                | ...                          | ...   |
| 9/14/2020 13:14:34 | R_LPPS_P4_MPR_Trip_Volt_Undr | LPPS Pump 4 MPR Undervoltage Trip           |
| 9/14/2020 13:14:17 | R_LPPS_P1_PQM_Volt_Sag       | LPPS Pump 1 Power Quality Meter Voltage Sag |
| 9/14/2020 13:14:17 | R_LPPS_P1_PQM_Phase_Loss     | LPPS Pump 1 Power Quality Meter Phase Loss  |
| 9/14/2020 13:14:07 | R_LPPS_P2_PQM_Phase_Loss     | LPPS Pump 2 Power Quality Meter Phase Loss  |
| 9/14/2020 13:14:07 | R_LPPS_P2_PQM_Volt_Sag       | LPPS Pump 2 Power Quality Meter Voltage Sag |
| 9/14/2020 13:13:53 | R_LPPS_P3_PQM_Volt_Sag       | LPPS Pump 3 Power Quality Meter Voltage Sag |
| 9/14/2020 13:13:53 | R_LPPS_P3_PQM_Phase_Loss     | LPPS Pump 3 Power Quality Meter Phase Loss  |
| 9/14/2020 13:13:34 | R_LPPS_P4_PQM_Volt_Sag       | LPPS Pump 4 Power Quality Meter Voltage Sag |
| 9/14/2020 13:13:34 | R_LPPS_P4_PQM_Phase_Loss     | LPPS Pump 4 Power Quality Meter Phase Loss  |
| 9/11/2020 22:00:40 | R_LPPS_P1_PQM_Volt_Sag       | LPPS Pump 1 Power Quality Meter Voltage Sag |
| 9/11/2020 22:00:40 | R_LPPS_P1_PQM_Phase_Loss     | LPPS Pump 1 Power Quality Meter Phase Loss  |
| 9/11/2020 22:00:39 | R_LPPS_P3_PQM_Volt_Sag       | LPPS Pump 3 Power Quality Meter Voltage Sag |
| 9/11/2020 22:00:39 | R_LPPS_P3_PQM_Phase_Loss     | LPPS Pump 3 Power Quality Meter Phase Loss  |
| 9/11/2020 22:00:39 | R_LPPS_P2_PQM_Volt_Sag       | LPPS Pump 2 Power Quality Meter Voltage Sag |
| 9/11/2020 22:00:39 | R_LPPS_P2_PQM_Phase_Loss     | LPPS Pump 2 Power Quality Meter Phase Loss  |
| 9/11/2020 22:00:38 | R_LPPS_P4_PQM_Volt_Sag       | LPPS Pump 4 Power Quality Meter Voltage Sag |
| 9/11/2020 22:00:38 | R_LPPS_P4_PQM_Phase_Loss     | LPPS Pump 4 Power Quality Meter Phase Loss  |
| 9/10/2020 09:32:49 | R_LPPS_P3_MPR_Trip_Volt_Undr | LPPS Pump 3 MPR Undervoltage Trip           |
| 9/10/2020 09:32:49 | R_LPPS_P1_MPR_Trip_Volt_Undr | LPPS Pump 1 MPR Undervoltage Trip           |



# Pump Performance Report



## Luther Pass Pump Station Pump Performance Report


Start Date: 2020-04-01 00:00:00  
End Date: 2020-07-01 00:00:00

### Performance Values from End of Report Period

|                    | Pump 1    | Pump 2    | Pump 3    | Pump 4    |
|--------------------|-----------|-----------|-----------|-----------|
| Design capacity    | 1,740 gpm | 1,740 gpm | 2,410 gpm | 2,410 gpm |
| Tested capacity    | 1,599 gpm | 1,312 gpm | 2,347 gpm | 2,467 gpm |
| Tested % of design | 92 %      | 75 %      | 97 %      | 102 %     |
| Tested efficiency  | 70.91 %   | 58.50 %   | 68.84 %   | 71.63 %   |


### Maximum Measurements During Report Period

|                          | Pump 1    | Pump 2    | Pump 3    | Pump 4    |
|--------------------------|-----------|-----------|-----------|-----------|
| Motor Vibration Inboard  | 0.07 in/s | 0.09 in/s | 0.12 in/s | 0.20 in/s |
| Motor Vibration Outboard | 0.06 in/s | 0.10 in/s | 0.16 in/s | 0.18 in/s |
| Pump Vibration Inboard   | 0.08 in/s | 0.85 in/s | 0.16 in/s | 0.92 in/s |
| Pump Vibration Outboard  | 0.08 in/s | 0.55 in/s | 0.27 in/s | 0.64 in/s |
| Winding Temp.            | 108 °F    | 160 °F    | 221 °F    | 225 °F    |
| Bearing Temp.            | 90 °F     | 144 °F    | 118 °F    | 154 °F    |
| Housing Temp.            | 79 °F     | 70 °F     | 75 °F     | 77 °F     |






# SJW Operations

- 
- 100 Pressure Zones
  - 84 Stations For Groundwater Extraction and/or Inter-Zone Pumping
  - 229 Booster Pumps & 83 Groundwater Well Pumps
    - 27 BG Annually

# Costs of Pumping



- 92% of Energy Use
  - ~40,000,000 kWh

\$\$\$




- Limited Monitoring = Reactive Maintenance
  - System Strain
  - Service Interruption
  - More Costly Repair/Replacement

\$




- Pump Prioritization Reliant on Field Efficiency Tests
  - Resource demanding
  - Infrequent
    - Data is Often 2-5 Years Old

# PI System



# Implementation





# Application: Alerts

- Pump

- Efficiency < Threshold
- Pump Degradation > Threshold
- Max kW @ Peak ToU > Threshold
- Pump On @ Peak ToU





Instructions: Select first Attribute from drop down (E9) and adjust Start and End Time (\* = current time, d = days, m = minutes, s = seconds or enter date (mm/dd/yyyy)) to customize search. Click Esc at anytime to stop a calculation.  
 \*May take a min or two to load  
 \*\*Best to copy and paste values to new sheet after calculations finish to then filter and sort results.




## All Pumps Attribute Totals

Total an attribute's data for all pumps

| Start Time | 3/1/2022                   | Attribute Description   | Total Peak kWh consumption over last run cycle |             |                                   |                    |            |                  |                       |
|------------|----------------------------|-------------------------|--|-------------|-----------------------------------|--------------------|------------|------------------|-----------------------|
| End Time   | 3/3/2022                   |                         |  |             |                                   |                    |            |                  |                       |
| Station    | Asset                      | Attribute               | UOM  | Data Status | Total Value                       | Time Running (hrs) | Inlet Zone | Outlet Zone      |                       |
| 29         | Breeding Avenue Station    | Breeding B-1            | IPeak kWh Sum                                  | kWh         | Complete                          | 15.76              | 498.22     | Suction Tank     | Cambrian Zone         |
| 31         | Breeding Avenue Station    | Breeding W-2            | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 0.19               | 498.12     | Groundwater      | Suction Tank          |
| 36         | Buena Vista Station        | Buena Vista B-3         | IPeak kWh Sum                                  | kWh         | Complete                          | 5.02               | 564.53     | Suction Tank     | Dow Zone              |
| 37         | Buena Vista Station        | Buena Vista B-4         | IPeak kWh Sum                                  | kWh         | Complete                          | 3.64               | 560.15     | Suction Tank     | Dow Zone              |
| 41         | Buena Vista Station        | Buena Vista W-13        | IPeak kWh Sum                                  | kWh         | Complete                          | 0.49               | 178.08     | Groundwater      | Suction Tank          |
| 43         | Buena Vista Station        | Buena Vista W-6         | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 0.59               | 250.37     | Groundwater      | Suction Tank          |
| 70         | Cox Avenue Station         | Cox B-4                 | IPeak kWh Sum                                  | kWh         | Missing Inlet and Outlet Pressure | 6.46               | 94.58      | Cox Zone         | Prospect Zone         |
| 72         | Cox Avenue Station         | Cox B-6                 | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 9.65               | 496.77     | Cox Zone         | Vickery Zone          |
| 73         | Cox Avenue Station         | Cox B-7                 | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 18.42              | 533.20     | Cox Zone         | Vickery Zone          |
| 79         | Elwood Road Station        | Elwood B-1              | IPeak kWh Sum                                  | kWh         | Complete                          | 3.50               | 498.86     | Belgatos Zone    | Webb Canyon Zone      |
| 81         | Fleming Avenue Station     | Fleming B-1             | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 1.88               | 301.11     | Cambrian Zone    | Miguelito Zone        |
| 95         | Greenridge Terrace Station | Greenridge B-1          | IPeak kWh Sum                                  | kWh         | Missing Outlet Pressure           | 2.90               | 40.15      | Greenridge Zone  | Highlands Zone        |
| 103        | High Street Station        | High Street B-1         | IPeak kWh Sum                                  | kWh         | Complete                          | 1.02               | 77.43      | High Street Zone | Mireval Zone          |
| 126        | McLaughlin Station         | McLaughlin W-2          | IPeak kWh Sum                                  | kWh         | Missing Inlet and Outlet Pressure | 0.29               | 0.48       | Groundwater      | Suction Tank          |
| 135        | Meridian Avenue Station    | Meridian W-5            | IPeak kWh Sum                                  | kWh         | Complete                          | 0.01               | 262.67     | Groundwater      | Suction Tank          |
| 151        | Needles Station            | Needles W-3             | IPeak kWh Sum                                  | kWh         | Incorrect Inlet Pressure          | 27.82              | 443.84     | Groundwater      | Dow Zone              |
| 162        | Pavilion Station           | Pavilion B-2            | IPeak kWh Sum                                  | kWh         | Missing Outlet Pressure           | 4.29               | 77.12      | Pavilion Zone    | Locust Reservoir Zone |
| 164        | Phillips Avenue Station    | Phillips B-1            | IPeak kWh Sum                                  | kWh         | Complete                          | 3.76               | 92.12      | Mt. Springs Zone | High Street Zone      |
| 179        | Seven Mile Station         | Seven Mile B-9          | IPeak kWh Sum                                  | kWh         | Complete                          | 7.67               | 263.77     | Dow Zone         | Greenridge Zone       |
| 180        | Seventeenth Street Station | Seventeenth Street B-1  | IPeak kWh Sum                                  | kWh         | Complete                          | 2.35               | 403.15     | Suction Tank     | Cambrian Zone         |
| 182        | Seventeenth Street Station | Seventeenth Street W-11 | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 0.15               | 310.78     | Groundwater      | Suction Tank          |
| 188        | Seventeenth Street Station | Seventeenth Street W-7  | IPeak kWh Sum                                  | kWh         | Complete                          | 0.16               | 171.79     | Groundwater      | Suction Tank          |
| 196        | Three Mile Station         | Three Mile W-3          | IPeak kWh Sum                                  | kWh         | Incorrect Inlet Pressure          | 0.16               | 261.94     | Groundwater      | Suction Tank          |
| 202        | Tully Road Station         | Tully B-2               | IPeak kWh Sum                                  | kWh         | Complete                          | 1.46               | 350.88     | Suction Tank     | Dow Zone              |
| 203        | Tully Road Station         | Tully B-3               | IPeak kWh Sum                                  | kWh         | Complete                          | 57.31              | 234.79     | Suction Tank     | Dow Zone              |
| 204        | Tully Road Station         | Tully W-1               | IPeak kWh Sum                                  | kWh         | Complete                          | 1.95               | 253.56     | Groundwater      | Suction Tank          |
| 205        | Tully Road Station         | Tully W-2               | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 1.18               | 115.92     | Groundwater      | Suction Tank          |
| 206        | Tully Road Station         | Tully W-3               | IPeak kWh Sum                                  | kWh         | Incorrect Inlet Pressure          | 1.27               | 127.60     | Groundwater      | Suction Tank          |
| 207        | Tully Road Station         | Tully W-4               | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 3.22               | 224.41     | Groundwater      | Suction Tank          |
| 208        | Tully Road Station         | Tully W-5               | IPeak kWh Sum                                  | kWh         | Complete                          | 1.19               | 76.85      | Groundwater      | Suction Tank          |
| 209        | Twelfth Street Station     | Twelfth Street B-1      | IPeak kWh Sum                                  | kWh         | Complete                          | 615.16             | 0.00       | Suction Tank     | Cambrian Zone         |
| 210        | Twelfth Street Station     | Twelfth Street B-2      | IPeak kWh Sum                                  | kWh         | Complete                          | 268.08             | 0.00       | Suction Tank     | Cambrian Zone         |
| 211        | Twelfth Street Station     | Twelfth Street B-3      | IPeak kWh Sum                                  | kWh         | Complete                          | 5.00               | 0.00       | Suction Tank     | Dow Zone              |
| 215        | Twelfth Street Station     | Twelfth Street W-11     | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 26.93              | 0.00       | Groundwater      | Suction Tank          |
| 216        | Twelfth Street Station     | Twelfth Street W-12     | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 27.09              | 0.00       | Groundwater      | Suction Tank          |
| 217        | Twelfth Street Station     | Twelfth Street W-13     | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 39.81              | 0.00       | Groundwater      | Suction Tank          |
| 218        | Twelfth Street Station     | Twelfth Street W-14     | IPeak kWh Sum                                  | kWh         | Complete                          | 14.49              | 0.00       | Groundwater      | Suction Tank          |
| 221        | Twelfth Street Station     | Twelfth Street W-6      | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 24.60              | 0.00       | Groundwater      | Suction Tank          |
| 222        | Twelfth Street Station     | Twelfth Street W-8      | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 27.47              | 0.00       | Groundwater      | Suction Tank          |
| 223        | Twelfth Street Station     | Twelfth Street W-9      | IPeak kWh Sum                                  | kWh         | Missing Inlet Pressure            | 49.20              | 0.00       | Groundwater      | Suction Tank          |


# Expanding & Improving Coverage

- Calibration
- Replacement
- New Installation











# Automated Pump Ranking



# Estimated Savings

- Peak  Off Peak  **\$540,000 / Year**
  - 30 Pumps/Mon Unintentionally On During Peak
- Prioritizing Most Efficient Pump  2%  Eff.
- 2%  Efficiency  **\$210,000 / Year**
  - i.e., 800,000 kWh Reduction
  - = 564 metric tons of CO<sub>2</sub>**