

MARCH 2023


Success Story with the AVEVA PI System

San Jose Water

ASCA Product Specialist Team

AVEVA | **SELECT**
CALIFORNIA


Pump Optimization: An Application of the AVEVA PI System




SAN JOSE WATER

SJW Operations

- 100 Pressure Zones
- 84 Stations For Groundwater Extraction and/or Inter-Zone Pumping
- 229 Booster Pumps & 83 Groundwater Well Pumps
- 27 BG Annually



Costs of Pumping



- 92% of Energy Use
 - ~40,000,000 kWh




- Limited Monitoring = Reactive Maintenance
 - System Strain
 - Service Interruption
 - More Costly Repair/Replacement




- Pump Prioritization Reliant on Field Efficiency Tests
 - Resource demanding
 - Infrequent
 - Data is Often 2-5 Years Old


Independent Data Sources



PI System



Implementation



Application: Alerts

- Pump


- Efficiency < Threshold
- Pump Degradation > Threshold
- Max kW @ Peak ToU > Threshold
- Pump On @ Peak ToU





Station Level (Booster/Well)

Asset: **Seventeenth Street Station**



Seventeenth Street Station


Well with Booster Station

Off

PG&E Info	
Rate Schedule	B19S
Current Rate Charge	0.1267 \$/kWh
Current Rate Category	Off Peak
Bill Start Date	3/1/2022 12:00:00 AM
Bill End Date	4/1/2022 12:00:00 AM
Avg Rate Over Bill Period	0.081998 \$/kWh

Local Weather	
San Jose/Reid/Hillv 3/29/2022 9:00:04 PM	
Temperature	53 °F
Last Hr Precipitation	0.00 in
Wind Speed & Deg.	6.78 mi/h 327
Humidity	76.5 %
Conditions	Mostly Clear

Overall Pump Performance		OPE & Cost per Million Gal	
Booster Pumps	Off	Last Cycle Avg	
0 of 2 Running		69 % OPE	
		83 \$/MG	
Well Pumps	Off	Last Cycle Avg	
0 of 7 Running		70 % OPE	
		119 \$/MG	



Booster Pumps

Seventeenth Street B-1

Real-Time | Last Cycle Avg

80

120

Seventeenth Street V

3/22/2022 9:00:04 PM



7d



Now

3/29/2022 9:00:04 PM

Instructions: Select first Attribute from drop down (E9) and adjust Start and End Time (* = current time, d = days, m= minutes, s= seconds or enter date (mm/dd/yyyy)) to customize search. Click Esc at anytime to stop a calculation.
 *May take a min or two to load
 **Best to copy and paste values to new sheet after calculations finish to then filter and sort results.



All Pumps Attribute Totals




Total an attribute's data for all pumps

Start Time	3/1/2022	Attribute Description	Total Peak kWk consumption over last run cycle							
End Time	3/31/2022	Station	Asset	Attribute	UOM	Data Status	Total Value	Time Running (hrs)	Inlet Zone	Outlet Zone
29	Breeding Avenue Station	Breeding B-1	IPeak kWh Sum	kWh	Complete	15.76	498.22	Suction Tank	Cambrian Zone	
31	Breeding Avenue Station	Breeding W-2	IPeak kWh Sum	kWh	Missing Inlet Pressure	0.19	498.12	Groundwater	Suction Tank	
36	Buena Vista Station	Buena Vista B-3	IPeak kWh Sum	kWh	Complete	5.02	564.53	Suction Tank	Dow Zone	
37	Buena Vista Station	Buena Vista B-4	IPeak kWh Sum	kWh	Complete	3.64	560.15	Suction Tank	Dow Zone	
41	Buena Vista Station	Buena Vista W-13	IPeak kWh Sum	kWh	Complete	0.49	178.08	Groundwater	Suction Tank	
43	Buena Vista Station	Buena Vista W-6	IPeak kWh Sum	kWh	Missing Inlet Pressure	0.59	250.37	Groundwater	Suction Tank	
70	Cox Avenue Station	Cox B-4	IPeak kWh Sum	kWh	Missing Inlet and Outlet Pressure	6.46	94.58	Cox Zone	Prospect Zone	
72	Cox Avenue Station	Cox B-6	IPeak kWh Sum	kWh	Missing Inlet Pressure	9.65	496.77	Cox Zone	Vickery Zone	
73	Cox Avenue Station	Cox B-7	IPeak kWh Sum	kWh	Missing Inlet Pressure	18.42	533.20	Cox Zone	Vickery Zone	
79	Elwood Road Station	Elwood B-1	IPeak kWh Sum	kWh	Complete	3.50	498.86	Belgatos Zone	Webb Canyon Zone	
81	Fleming Avenue Station	Fleming B-1	IPeak kWh Sum	kWh	Missing Inlet Pressure	1.88	301.11	Cambrian Zone	Miguelito Zone	
95	Greenridge Terrace Station	Greenridge B-1	IPeak kWh Sum	kWh	Missing Outlet Pressure	2.90	40.15	Greenridge Zone	Highlands Zone	
103	High Street Station	High Street B-1	IPeak kWh Sum	kWh	Complete	1.02	77.43	High Street Zone	Mireval Zone	
126	McLaughlin Station	McLaughlin W-2	IPeak kWh Sum	kWh	Missing Inlet and Outlet Pressure	0.29	0.48	Groundwater	Suction Tank	
135	Meridian Avenue Station	Meridian W-5	IPeak kWh Sum	kWh	Complete	0.01	262.67	Groundwater	Suction Tank	
151	Needles Station	Needles W-3	IPeak kWh Sum	kWh	Incorrect Inlet Pressure	27.82	449.84	Groundwater	Dow Zone	
162	Pavilion Station	Pavilion B-2	IPeak kWh Sum	kWh	Missing Outlet Pressure	4.29	77.12	Pavilion Zone	Locust Reservoir Zone	
164	Phillips Avenue Station	Phillips B-1	IPeak kWh Sum	kWh	Complete	3.76	92.12	Mt. Springs Zone	High Street Zone	
179	Seven Mile Station	Seven Mile B-9	IPeak kWh Sum	kWh	Complete	7.67	263.77	Dow Zone	Greenridge Zone	
180	Seventeenth Street Station	Seventeenth Street B-1	IPeak kWh Sum	kWh	Complete	2.35	403.15	Suction Tank	Cambrian Zone	
182	Seventeenth Street Station	Seventeenth Street W-11	IPeak kWh Sum	kWh	Missing Inlet Pressure	0.15	310.78	Groundwater	Suction Tank	
188	Seventeenth Street Station	Seventeenth Street W-7	IPeak kWh Sum	kWh	Complete	0.16	171.79	Groundwater	Suction Tank	
196	Three Mile Station	Three Mile W-3	IPeak kWh Sum	kWh	Incorrect Inlet Pressure	0.16	261.94	Groundwater	Suction Tank	
202	Tully Road Station	Tully B-2	IPeak kWh Sum	kWh	Complete	1.46	350.88	Suction Tank	Dow Zone	
203	Tully Road Station	Tully B-3	IPeak kWh Sum	kWh	Complete	57.31	234.79	Suction Tank	Dow Zone	
204	Tully Road Station	Tully W-1	IPeak kWh Sum	kWh	Complete	1.95	253.56	Groundwater	Suction Tank	
205	Tully Road Station	Tully W-2	IPeak kWh Sum	kWh	Missing Inlet Pressure	1.18	115.92	Groundwater	Suction Tank	
206	Tully Road Station	Tully W-3	IPeak kWh Sum	kWh	Incorrect Inlet Pressure	1.27	127.60	Groundwater	Suction Tank	
207	Tully Road Station	Tully W-4	IPeak kWh Sum	kWh	Missing Inlet Pressure	3.22	224.41	Groundwater	Suction Tank	
208	Tully Road Station	Tully W-5	IPeak kWh Sum	kWh	Complete	1.19	76.85	Groundwater	Suction Tank	
209	Twelfth Street Station	Twelfth Street B-1	IPeak kWh Sum	kWh	Complete	615.16	0.00	Suction Tank	Cambrian Zone	
210	Twelfth Street Station	Twelfth Street B-2	IPeak kWh Sum	kWh	Complete	268.08	0.00	Suction Tank	Cambrian Zone	
211	Twelfth Street Station	Twelfth Street B-3	IPeak kWh Sum	kWh	Complete	5.00	0.00	Suction Tank	Dow Zone	
215	Twelfth Street Station	Twelfth Street W-11	IPeak kWh Sum	kWh	Missing Inlet Pressure	26.93	0.00	Groundwater	Suction Tank	
216	Twelfth Street Station	Twelfth Street W-12	IPeak kWh Sum	kWh	Missing Inlet Pressure	27.09	0.00	Groundwater	Suction Tank	
217	Twelfth Street Station	Twelfth Street W-13	IPeak kWh Sum	kWh	Missing Inlet Pressure	39.81	0.00	Groundwater	Suction Tank	
218	Twelfth Street Station	Twelfth Street W-14	IPeak kWh Sum	kWh	Complete	14.49	0.00	Groundwater	Suction Tank	
221	Twelfth Street Station	Twelfth Street W-6	IPeak kWh Sum	kWh	Missing Inlet Pressure	24.60	0.00	Groundwater	Suction Tank	
222	Twelfth Street Station	Twelfth Street W-8	IPeak kWh Sum	kWh	Missing Inlet Pressure	27.47	0.00	Groundwater	Suction Tank	
223	Twelfth Street Station	Twelfth Street W-9	IPeak kWh Sum	kWh	Missing Inlet Pressure	49.20	0.00	Groundwater	Suction Tank	

Single Pump Sample Data | Single Pump Attribute Avg | All Pump Attribute Avgs | Paste Here | **All Pump Attribute Totals** ...

Ready Filter Mode

Estimated Savings

- Peak  Off Peak \equiv **\$540,000 / Year**
 - 30 Pumps/Mon Unintentionally On During Peak
- Prioritizing Most Efficient Pump \equiv 2%  Eff.
- 2%  Efficiency \equiv **\$210,000 / Year**
 - i.e., 800,000 kWh Reduction
 - = 564 metric tons of CO₂**

Overall Results

- Dissolve Data Silos
- Real-time Performance Monitoring and Alerts
- Exportable Performance Data
- Real-Time Data Driven Pump & Station Prioritization
- Expected ROI < 1 Yr

- Date

████████████████████

- Title

- Subtitle

 [linkedin.com/company/aveva](https://www.linkedin.com/company/aveva)

 @avevagroup

ABOUT AVEVA

AVEVA is a global leader in engineering and industrial software driving digital transformation across the entire asset and operational life cycle of capital-intensive industries.

- ASCA Product Specialist, Team

The company's engineering, planning and operations, asset performance, and monitoring and control solutions deliver proven results to over 16,000 customers across the globe. Its customers are supported by the largest industrial software ecosystem, including 4,200 partners and 5,700 certified developers. AVEVA is headquartered in Cambridge, UK, with over 4,400 employees at 80 locations in over 40 countries.

[aveva.com](https://www.aveva.com)